


- LEGEND**
- Pending
 - LED: 74W
 - LED: 96W
 - LED: 125W
 - Removed by CSD request
 - Pole mounted bracket on ENE pole (with demarcation box and 2P MCB)
 - Wall mounted bracket (with demarcation box and 2P MCB)
 - Pole mounted bracket on Pipe pole (with demarcation box and 2P MCB)
 - New 8m Pole (with cutout unit and 2P 30mA RCBO)
 - Retrofitting of existing ENE Pole



REV	DATE	BY	ALTERATION	APPD	REV	DATE	BY	ALTERATION	APPD
F	24/06/20	Eng.G.MIFSUD	Separated Retrofitted poles from new poles	Ing.E.LEWIS	A	13/11/19	Eng.G.MIFSUD	Installed Light fittings with ID no.	Ing.E.LEWIS
G	30/09/20	Eng.G.MIFSUD	Marked last lighting at Cannon rd as installed	Ing.E.LEWIS	B	20/11/19	Eng.G.MIFSUD	Revised colour coding of light fittings wattages	Ing.E.LEWIS
H	13/05/21	Eng.G.MIFSUD	Updated drawing with latest S/L	Ing.E.LEWIS	C	21/02/20	Eng.G.MIFSUD	Updated Light fittings ID no.	Ing.E.LEWIS
I	19/05/22	Eng.G.MIFSUD	Updated drawing with latest S/L	Ing.E.LEWIS	D	13/05/20	Eng.G.MIFSUD	Updated Light fittings ID no.	Ing.E.LEWIS
J	19/08/22	Eng.G.MIFSUD	Updated drawing with latest S/L	Ing.E.LEWIS	E	04/06/20	Eng.G.MIFSUD	Updated Light fittings ID no. & included type of installation	Ing.E.LEWIS

DRAWN BY		CHECKED BY		APPROVED BY		CONTACT		LDC OF FILE	
Eng.G.MIFSUD	Eng.G.MIFSUD	Eng.G.MIFSUD	Eng.G.MIFSUD	Ing.E.LEWIS	Ing.E.LEWIS	7907	3670		

DIMENSIONS IN mm	
SCALE: N.T.S.	PAGE: 1/1
DRAWING No. CDS-065/19	REFERENCE No. 1
DERIVED FROM	-

Upgrading of street lighting at the Industrial Estate of Mriehel